

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 608/2025/श.न.न.श.स.

Dated: 8/5/2025

It is certified that an inspection team headed by S.K. Katiyar, SFI

(Name of Officers with designation) from Nagar Nigam Shahjahanpur PHED

inspected the DOON INTERNATIONAL SCHOOL, Shahjahanpur

(Name & Address of the school) on 7/5/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no SFPRC/25050/106-06 dated 5/5/2025

of SHIRAM FOOD & PHARMA RESEARCH CENTRE

(PHED

Lab)

certified

that

the

DOON INTERNATIONAL SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 3 Years (7/5/2028)

Signature with Seal:

Name

Designation

Name & Address of the Office / Department:

नगर स्वास्थ्य अधिकारी
नगर निगम
शाहजहाँपुर /

Manoj Mishra
Nagar Swasthya Adhikari


NAGAR NIGAM, SHAHJAHANPUR
(U.P) (242001)

To DOON INTERNATIONAL SCHOOL,

NIWAR PUR, P.O. DALELGUNJ, RCMISSION,

(Name & Address of the Institution) SHAHJAHANPUR
U.P. (242001)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


Manager/Secretary
Doon International School
Shahjahanpur-242001 (U.P.)


Principal
Doon International School
Shahjahanpur 242001 (U.P.)



SHRIRAM FOOD & PHARMA RESEARCH CENTRE

TEST REPORT

*Issued To: Doon International School		ULR No.	NA
Address: Niwazpur, PO Dalelganj, Thana RC Mission Shahjahanpur, Uttar Pradesh, Shahjahanpur-242001		Report No.	SFPRC/250501106-06
*Sample Name	RO Water	Sample Receipt Date	01/05/2025
*Sample Qty.	1 Ltr.	Report Issue Date	05/05/2025
*Mfg. by	NA	Start Date of Analysis	01/05/2025
*Mfg. Date	NA	Date of Completion	05/05/2025
Exp. Date/Best Before	NA	Sample Condition	OK
*Batch No./Lot No.	NA	Sample Packing Mode	Glass Bottle
Any other information		Date of Sampling	NA
		Sampling SOP/Plan No.	NA
		Sampling Done by	Customer
		Environmental Condition	Temp.: 25 ± 5°C Humidity: 50 ± 20% RH

Page: 1 of 2

RESULT ANALYSIS						
S. No	Test Parameters	Units of Measurements	Results	As per IS 10500:2012 Acceptable Limit	As per IS 10500:2012 Permissible Limit	Method Reference
Table 1: Organoleptic and Physical Parameters						
1	Colour	Hazen	BLO (LOG-0)	5 Max.	15 Max.	IS 3025 (Part-4) 2021
2	Odour		Agreeable	Agreeable	Agreeable	IS 3025 (Part-6) 2018
3	pH		7.24	6.5 - 8.5	No relaxation	IS 3025 (Part-11) 2022
4	Potassium	mg/l	15			IS 3025 (Part-45) 1993
5	Total Dissolved Solid	mg/l	154	500 Max.	2000 Max.	IS 3025 (Part-16) 1994
Table 2: General Parameters Concerning Substances Undesirable in Excessive Amounts						
6	Calcium (as Ca)	mg/l	19	75 Max.	200 Max.	IS 3025 (Part-40) 1991
7	Sodium	mg/l	20			IS 3025 (Part-45) 1993
8	Fluoride (as F)	mg/l	BLO (LOG-0.01)	1.0 Max.	1.5 Max.	IS 3025 (Part-60) 2008
9	Iron (as Fe)	mg/l	0.05	1.0 Max.	No relaxation	IS 3025 (Part-53) 2003

[Signature]
Manager/Secretary
Doon International School
Shahjahanpur-242001 (U.P.)

[Signature]
Principal
Doon International School
Shahjahanpur-242001 (U.P.)





SHRIRAM FOOD & PHARMA RESEARCH CENTRE

Report No. : SFPRC/250501106-06

Page No. 2 of 2

S. No	Test Parameters	Units of Measurements	Results	As per IS 10500:2012 Acceptable Limit	As per IS 10500:2012 Permissible Limit	Method Reference
10.	Electrical Conductivity	µmhos/cm	397	-	-	IS 3025 (Part-14): 1984
11.	Total alkalinity (as CaCO ₃)	mg/l	16	200 Max.	600 Max.	IS 3025 (Part-23): 1986
12.	Total Hardness (as CaCO ₃)	mg/l	62	200 Max.	600 Max.	IS 3025 (Part-21): 2009
13.	Total Chlorine	mg/l	BLQ (LOQ-0.05)	-	-	IS 3025 (Part-26): 2021
14.	Lead (as Pb)	mg/l	BLQ (LOQ-0.001)	0.01 Max.	No relaxation	IS :3025 (Part-65): 2022
15.	Total arsenic (as As)	mg/l	BLQ (LOQ-0.001)	0.01 Max.	0.05 Max.	IS :3025 (Part-65): 2022
Microbiological Parameters :-						
16.	E. coli	Per 100 ml	Absent	Shall not be detectable		IS: 15185-(2016)
17.	Coliform	Per 100 ml	Absent	Shall not be detectable		IS: 15185-(2016)


Note: - BLQ-Below Limit of Quantification, LOQ-Limit of Quantification, NA- Not Available.

Remarks: - The sample meets the requirements of IS 10500: 2021 (Acceptable Limit) with respect the above test only.

— End of Test Report—



REVIEWED BY



AUTHORISED SIGNATORY
(Microbiological)



AUTHORISED SIGNATORY
(Chemical)

Remarks: 1. The Results listed refer only to the above tested sample & applicable parameters. Endorsement of products is neither inferred nor implied.
2. Liability of laboratory is limited to the invoiced amount only.
3. The sample(s) of Drugs & Cosmetics will be destroyed after one year. Perishable samples (Other than Drugs & Cosmetics) will be destroyed after 7 days and non perishable samples will be destroyed after 30 days of the date of issue of test report or unless otherwise specified.
4. Laboratory will not be held responsible for the authenticity of any photocopied, forged and or partially presented test reports.
5. Laboratory will ensure all corrective action as per our policy in case of any discrepancy in any sample tested by the Laboratory.
6. Re-testing charges will be applicable in case the results are reproducible.
7. This report is not to be reproduced wholly or in part and cannot be used as an evidence in the Court of law and shall not be used in the advertising media without our prior permission from the CEO.

* Indicates details provided by the customer

Manager/Secretary
Doon International School
Shahjahanpur-242001 (U.P.)

Principal
Doon International School
Shahjahanpur 242001 (U.P.)

AO-150, 2nd Floor, Amrit Steel Compound South Side, G.T. Road Industrial Area, Ghaziabad-201001 UP, India

0120-3512782, 9811064899 ■ info@shriramlab.org ■ www.shriramlab.org

